Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Standard Components 1250 Department Room Tag: **Anaesthetic Store Room Name Room Code: ANST-SJ**

Net Room Area Briefed

20.0 M2

No of Rooms

Subtotal of Briefed Area

20.00 M2

Hours of Operation

Available 24 Hours

Occupancy

2 - 3

Also covers these Rooms

Description/ **Special Requirements**

The Anaesthetic Store provides an area for storage of anaesthetic consumables, monitors and spare parts for anaesthetic equipment, within the Operating Unit.

Amendment

13.03.2014 First issue

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9125	Doors	Solid Core/ Glass	Paint	1 1/2 leaf, observation panel		1400mm clear opening, door optional
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL		

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1050	Bench: laminate	Furniture/ Fitting	1	1	
4375	Cupboard: medication, lockable	Furniture/ Fitting	1	1	
4420	Cupboard: under bench, lockable	Furniture/ Fitting	1	1	adjustable shelves
4470	Cupboard: wall mounted, lockable	Furniture/ Fitting	1	1	over bench, adjustable shelves
12900	Louvred panel: for storage-bins	Metalwork	1	4	above bench
13660	Metal shelving: 900x400x2100	Furniture/ Fitting	3	6	
20000	Shelving unit: adjustable	Furniture/ Fitting	1	1	over bench
23950	Trolley	Furniture/ Fitting	3	1	procedure
24400	Whiteboard	Furniture/ Fitting	2	1	900x900, optional

Issue Date: 1 Apr 2014

Sharjah Healthcare City - Health Facility Guidelines

Milestone: Current

Room Data Sheets

Page 2 of 2

Standard Components 1250 Department Room Tag: **Anaesthetic Store Room Name** Room Code: **ANST-SJ**

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	//mW	Тар	Dns	Gas	Selection / Remarks
43800	Refrigerator: under-bench, 120 Litre	3	1	yes								optional

Services

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone
5005	Air conditioning: special	HVAC		positive pressure, filtered
6000	General fluorescent	Lighting		
6055	Special: task light, built in	Lighting		under O/H cupboards
9001	GPO: Double	Power	4	
9000	GPO: Single	Power	1	refrigerator, under bench