#### **Sharjah Healthcare City - Health Facility Guidelines** Milestone: Current

**Room Data Sheets** 

Department	Standard Components	Room Tag:	1300
Room Name	Anteroom	Room Code:	ANRM-SJ

**Net Room Area Briefed** 

6.0 M2

No of Rooms

**Subtotal of Briefed Area** 

6.00 M2

**Hours of Operation** 

24 Hours

Occupancy

Also covers these Rooms 1 - 2

Description/ **Special Requirements** 

Anteroom or airlock associated with an Isolation room for maintenance of air pressurisation and for staff and visitors to change and dispose of protective gear used on entering or exit; a staff handwashing basin will be located within the room; glazing is recommended for patient visibility. Pressurisation - negative or positive depending on type of Isolation room

Body Protected electrical area

**Amendment** 

13.03.2014 First issue

### **Room Fabric and outline specifications**

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9115	Doors	Solid Core/ Glass	Paint	1 1/2 leaf, half glazed		1400mm clear opening
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3022	Wall finish	Resinate, 6mm	Prefinished	Splashback		to basin, tiles also acceptable

### Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
530	Basin vanity top	Furniture/ Fitting	1	1	
3400	Coathook	Metalwork	1	4	2 inside cupboard, 2 on wall
4391	Cupboard: special	Furniture/ Fitting	1	1	with shelves & flip door for linen carrier
4350	Cupboard: tall	Furniture/ Fitting	1	1	with hooks for hanging gowns
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin

Issue Date: 1 Apr 2014

# Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

**Room Data Sheets** 

DepartmentStandard ComponentsRoom Tag:1300Room NameAnteroomRoom Code:ANRM-SJ

ID	Description	Category	Group	Qty	Selection / Remarks
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
12300	Linen carrier: dirty, single	Furniture/ Fitting	3	1	in cupboard
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

## Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	<b>%mW</b>	Тар	Dns	Gas	Selection / Remarks
3120	Basin: vanity	1	1			yes		yes	yes	yes		Type B, elbow action
												levers

### **Services**

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		

Print Date: 20 May 2014 014 Page 2 of 2