Sharjah Healthcare City - Health Facility Guidelines

Room Data Sheets

Milestone: Current

Department Room Name	Standard Components Audiology Testing Room	Room Tag: Room Code:	1340 AUDIO-SJ						
Net Room Area Briefed	14.0 M2								
No of Rooms	1								
Subtotal of Briefed Area	14.00 M2								
Hours of Operation	8am to 6pm, daily								
Occupancy	Up to 3								
Also covers these Rooms									
Description/ Special Requirements	Room with an internal sound proof booth to specifications, for audiology testing. Audiometric booth should be ventilated or connected to airconditioning, power and data. Level access to the Audiometric Booth is recommended.								
	Acoustics: Acoustic privacy required								
	Body protected electrical area								
Amendment 13.03.2014 First issue									

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8000	Door protection	Vinyl	Prefinished	Kickplate, 300mm high		
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		920mm clear opening
1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom, 48 oz.		
949496	Skirting	Timber	Paint	150mmH x 20mm thick, nominal		
3000	Wall finish	Paint	Acrylic, washable			

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1600	Chair: child	Furniture/ Fitting	3	1	as required
1650	Chair: client	Furniture/ Fitting	3	3	
2100	Chair: ergonomic, office	Furniture/ Fitting	3	1	
3400	Coathook	Metalwork	1	2	
5900	Desk	Furniture/ Fitting	3	1	
17250	Pedestal drawer unit: mobile, 660mmH	Furniture/ Fitting	3	1	under desk
22780	Table: small	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	

Fixtures, Equipment and associated Services (FE)

ID	Description	GroupQty Ele	e Data CdWHtWNmWTap	Dns Gas Selection	n / Remarks
		Provided by TAHPI for :	Issue No: 1	Print Date:	20 May 2014
S	HCC Guidelines	Sharjah Domain	Issue Date: 1	Apr 2014	Page 1 of 2

Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Department Room Name	Standar Audiolog		-								oom ⁻ m Co	•	1340 AUDIO-SJ
udiometric booth		3	1	yes	yes							to specificati	on
elephone: handset, standar	d	3	1		yes							on desk	
	Room Name	Room Name Audiolo	Room Name Audiology Te udiometric booth 3	Room Name Audiology Testin udiometric booth 3	Room Name Audiology Testing Ro udiometric booth 3 1	Room Name Audiology Testing Room udiometric booth 3 1 yes	Room Name Audiology Testing Room udiometric booth 3 1 yes	Room Name Audiology Testing Room udiometric booth 3 1 yes	Room Name Audiology Testing Room udiometric booth 3 1 yes	Room Name Audiology Testing Room udiometric booth 3 1 yes	Room Name Audiology Testing Room Roo udiometric booth 3 1 yes	Room Name Audiology Testing Room Room Co udiometric booth 3 1 yes	Room Name Audiology Testing Room Room Code: udiometric booth 3 1 yes

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	2	1 to booth, 1 outlet to desk for telephone
5000	Airconditioning	HVAC		
6110	Downlights: dimmable	Lighting		
6000	General fluorescent	Lighting		
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	
9001	GPO: Double	Power	4	2- desk; 2-booth
9060	GPO: Special: for equipment	Power	1	audiometric booth
10005	Duress alarm	Security	1	