

Department	Standard Components	Room Tag:	1600
Room Name	Bay - Pathology	Room Code:	BPATH-SJ
Net Room Area Briefed	1.0 M2		
No of Rooms	1		
Subtotal of Briefed Area	1.00 M2		
Hours of Operation	24 Hours		
Occupancy	1		
Also covers these Rooms			
Description/ Special Requirements	The Pathology Bay provides an area for preparation, holding of patient specimens and may include processing of some patient specimens. The bay may be located in Critical Care Units or an Operating Unit.		
Amendment	13.03.2014 First issue		

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		tiles also acceptable
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL		

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1050	Bench: laminate	Furniture/ Fitting	1	1	with inset sink
4410	Cupboard: under bench	Furniture/ Fitting	1	1	under part bench, with adjustable shelf
4470	Cupboard: wall mounted, lockable	Furniture/ Fitting	1	1	over bench
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to sink
6156	Dispenser: soap	Furniture/ Fitting	2	1	to sink
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to sink
21680	Stool: adjustable, mobile	Furniture/ Fitting	3	1	under bench, optional
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	under bench

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	Cd	WH	TW	m	WT	Tap	Dns	Gas	Selection / Remarks
47800	Sink, SS: single in bench	1	1	___	___	yes	opt	opt	yes	yes	___	___	___	hot water
54510	Telephone: handset, standard	3	1	___	yes	___	___	___	___	___	___	___	___	to bench, optional

Services

Department
Room Name

Standard Components
Bay - Pathology

Room Tag: 1600
Room Code: BPATH-SJ

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	1	
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
6055	Special: task light, built in	Lighting		under O/H cupboards
9010	GPO: Emergency power, single	Power	1	
9000	GPO: Single	Power	1	