## **Sharjah Healthcare City - Health Facility Guidelines** Milestone: Current

**Room Data Sheets** 

Print Date: 20 May 2014

Page 1 of 1

Issue No: 1

Issue Date: 1 Apr 2014

Department	Standard Components	Room Tag:	1630
Room Name	Bay - Resuscitation Trolley	Room Code:	BRES-SJ

**Net Room Area Briefed** 

1.5 M2

No of Rooms

**Subtotal of Briefed Area** 

1.50 M2

**Hours of Operation** 

24 Hours

**Occupancy** 

N/A

Also covers these Rooms

Description/ **Special Requirements** 

A recessed bay to provide supervised holding of the resuscitation trolley and equipment. The bay should be located close to a Staff Station.

Special Design Requirements: The Bay shall be a minimum of 600mm deep.

**Amendment** 

13.03.2014 First issue

## **Room Fabric and outline specifications**

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500AFFL		As required
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900AFFL		

## Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
4460	Cupboard: wall mounted	Furniture/ Fitting	1	1	over trolley/s, optional
7400	Trolley: equipment	Furniture/ Fitting	3	1	as required
18800	Trolley: resuscitation, adult	Furniture/ Fitting	3	1	

## **Services**

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
9011	GPO: Emergency power, double	Power	2	for recharging emergency equipment