Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Department Room Name	Standard Components Blood Collection Work Area	Room Tag: Room Code:	1690 BLDCW-SJ
Net Room Area Briefed	12.0 M2		
No of Rooms	1		
Subtotal of Briefed Area	12.00 M2		
Hours of Operation	24 Hours		
Occupancy	1 - 2 staff		
Also covers these Rooms			
Description/ Special Requirements	The Blood Collection Work area provide of specimens and documentation, and w Blood Collection Bays.		-
Amendment	13.03.2014 First issue		

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5007	Ceiling	Plasterboard	Paint	Bulkhead		optional
5010	Ceiling	Plasterboard	Paint, washable			
6025	Cornice	Aluminium	Powdercoat	shadow line		
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		920mm clear opening, lockable
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		to basin & above bench
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900 AFFL		

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1050	Bench: laminate	Furniture/ Fitting	1	1	U shaped; 900AFFL
1470	Bracket: sharps	Furniture/ Fitting	2	1	mounted to trolley
4360	Cupboard: door ht adj. shelves	Furniture/ Fitting	1	1	lockable
4410	Cupboard: under bench	Furniture/ Fitting	1	2	with adjustable shelves
4470	Cupboard: wall mounted, lockable	Furniture/ Fitting	1	1	over bench; adjustable shelves
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to hand basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to hand basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to hand basin
12900	Louvred panel: for storage-bins	Metalwork	1	2	above bench, optional
19700	Sharps bin	Furniture/ Fitting	3	1	on trolley
21755	Storage bins	Furniture/ Fitting	3	5	for louvred panels, if provided
23950	Trolley	Furniture/ Fitting	3	1	

 Provided by TAHPI for :
 Issue No: 1
 Print Date:
 20 May 2014

 Sharjah Domain
 Issue Date: 1 Apr 2014
 Page 1 of 2

Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

	Department Room Name	Standar Blood C	1		Room Tag: Room Code:	1690 BLDCW-SJ	
ID	Description		Category	Group	Qty	Selection / Remarks	
24100	Waste bin: paper, 20 Litre		Furniture/ Fitting	3	1	to hand basin	

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	V mW	Тар	Dns	Gas	Selection / Remarks
2800	Basin: handwash, Type B	1	1			yes		yes	yes	yes		refer to BHWS-B (sim)
43800	Refrigerator: under-bench, 120 Litre	3	1	yes								
54510	Telephone: handset, standard	3	1		yes							

Services

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
6055	Special: task light, built in	Lighting		under O/H cupboards
9000	GPO: Single	Power	1	refrigerator, under bench
9000	GPO: Single	Power	4	