Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

DepartmentStandard ComponentsRoom Tag:2110Room NameCytotoxic RoomRoom Code:CYT-SJ

Net Room Area Briefed

8.0 M2

No of Rooms

1

Subtotal of Briefed Area

8.00 M2

Hours of Operation

24 Hours

Occupancy

1 - 2 intermittently

Also covers these

Rooms

Kooms

Description/ Special Requirements The Cytotoxic room provides for the storage and preparation of cytotoxic patient preparations including intravenous fluids and sterile items.

Amendment

13.03.2014 First issue

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		920mm clear opening, lockable
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 AFFL		tiles also acceptable

Fittings and Furniture (FF)

ID	Description	Category		Qty	Selection / Remarks
1050	Bench: laminate	Furniture/ Fitting	1	1	
4360	Cupboard: door ht adj. shelves	Furniture/ Fitting	1	1	lockable
4410	Cupboard: under bench	Furniture/ Fitting	1	1	with adjustable shelf
4470	Cupboard: wall mounted, lockable	Furniture/ Fitting	1	2	over bench, with adjustable shelf
12900	Louvred panel: for storage-bins	Metalwork	1	2	above bench, optional
19700	Sharps bin	Furniture/ Fitting	3	1	cytotoxic sharps

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	% mW	Тар	Dns	Gas	Selection / Remarks
43800	Refrigerator: under-bench, 120 Litre	3	1	yes								optional
54510	Telephone: handset, standard	3	1		yes							optional, on bench

Sharjah Healthcare City - Health Facility Guidelines Mi

Milestone: Current

Room Data Sheets

Department	Standard Components	Room Tag:	2110
Room Name	Cytotoxic Room	Room Code:	CYT-SJ

Services

ID	Description	Service Category	Qty	Selection / Remarks		
1006	Voice / Data outlet: double	Communications	1	optional		
5000	Airconditioning	HVAC				
6000	General fluorescent	Lighting				
6055	Special: task light, built in	Lighting		under O/H cupboards		
9000	GPO: Single	Power	1	Refrigerator, under bench		
9000	GPO: Single	Power	4			