Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Standard Components 4420 Department Room Tag: **Room Name** Store - General, 20m2 **Room Code:** STGN-20-SJ

Net Room Area Briefed

20.0 M2

No of Rooms

Subtotal of Briefed Area

20.00 M2

Hours of Operation

24 Hours

Occupancy

1 - 2 intermittently

a de-boxing area.

Also covers these

Special Requirements

Rooms

Description/

The General Store is a secure room for the storage of general supplies and non sterile items used within the Unit. The room may also be used as

Amendment

13.03.2014 - First Issue

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5030	Ceiling	Plasterboard	Prefinished	Drop-in tiles, 600x1200		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8040	Door protection	Composite	Prefinished PVC	To door frame		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
9001	Doors	Solid Core	Paint	Single leaf		920 mm clear opening; lockable
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
12900	Louvred panel: for storage-bins	Metalwork	1	3	1800H - optional
13660	Metal shelving: 900x400x2100	Furniture/ Fitting	3	13	
24400	Whiteboard	Furniture/ Fitting	2	1	optional

Services

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
9001	GPO: Double	Power	1	

Issue No: 1

Issue Date: 1 Apr 2014