

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name 1 Bed Bay - Critical Care

Room Code 1BB-CC

Area M2 20

Description Special Requirement

One Bed Bay for patient requiring critical care nursing and medical treatment; Visual access to Staff Station is required; Screen curtains are required for patient privacy. Maximum natural light is required to patient beds.

Acoustics: Acoustic privacy is required.

Cardiac Protected Electrical Area

Room Fabric and outline specifications

Remarks

1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	to basin, tiles also acceptable
3092	Wall protection	MDF	Laminate	Bed protection wall panel	
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
7055	Observation	Alum/glass	Anodised	Internal window, double glazed	to partition walls, with integral Venetians

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
1050	Furniture/ Fitting	Bench: laminate	1	1	optional
1252	Furniture/ Fitting	Blind: Venetian integral	1	3	to all windows, controls to both sides
1465	Furniture/ Fitting	Bracket: suction bottle	2	4	on equipment rail
1470	Metalwork	Bracket: sharps	2	1	to side of bench
4430	Furniture/ Fitting	Cupboard: drawer unit	1	1	under bench, optional
4430	Furniture/ Fitting	Cupboard: drawer unit	1	1	under bench, optional
4600	Metalwork	Curtain track, bed	1	1	
6152	Furniture/ Fitting	Dispenser: disposable glove	2	1	near entry
6153	Furniture/ Fitting	Dispenser: moisturiser	2	1	to basin
6154	Furniture/ Fitting	Dispenser: paper towel	2	1	to basin
6156	Furniture/ Fitting	Dispenser: soap	2	1	to basin
6158	Furniture/ Fitting	Dispenser: soap antiseptic	2	1	to basin
11200	Metalwork	IV track, ceiling mounted	1	1	optional
12900	Metalwork	Louvered panel, for storage-bins	1	2	457mm x 457mm, above bench
23400	Metalwork	Television bracket, ceiling	1	1	optional

Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quant	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
3100	Basin : scrub - large	1	1	___	yes	___	yes	yes	yes	___	___	wall mount, long lever taps
9700	Clock : analogue, wall	1	1	yes	___	___	___	___	___	___	___	
15985	Dialysis station	1	1	___	yes	___	yes	yes	yes	___	___	

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name **1 Bed Bay - Critical Care**

Room Code **1BB-CC**

FFE ID	Description	Grp	Quant	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
31700	Light : examination, ceiling	1	1	yes	___	___	___	___	___	___	___	
47000	Services : pendant, ceiling	1	1	yes	___	___	___	___	___	___	___	or panel

Services

Service ID	Service Category	Description	Quantity	Remarks
1006	Communications	Voice / Data outlet - double	1	to workstation
1006	Communications	Voice / Data outlet - double	1	services pendant/ panel
1090	Communications	TV: MATV	1	optional
1120	Communications	Monitor connection facilities and cabling	1	to central station
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
6001	Lighting	General : colour corrected		
6060	Lighting	Special: night lights		
7000	Medical Gases	O2	3	to services pendant/ panel
7020	Medical Gases	Medical Air	2	to services pendant/ panel
7040	Medical Gases	Suction	3	to services pendant/ panel
8000	Nurse Call	Patient / Nurse call	1	+ indicator button & light
8005	Nurse Call	Patient call handset	1	call button on the handset
8010	Nurse Call	Nurse assist call	1	+ indicator button & light
8080	Nurse Call	Emergency call	1	+ indicator button & light
9001	Power	GPO: Double	1	to bench (optional)
9010	Power	GPO: Single - emergency power	8	to services pendant/ panel
9010	Power	GPO: Single - emergency power	4	to wall (optional)
9015	Power	GPO: Cleaner	1	
9015	Power	GPO: Cleaner	1	
9030	Power	Cardiac Protected		
9060	Power	Special: for equipment	2	exam light, TV (if provided)