

# Design Guidelines for Hospitals and Day Procedure Centres

## Standard Components Room Data Sheets

**Room Name** ADL Bathroom

**Room Code** ADLB

**Area M2** 10

**Description** A Domestic style bathroom for patient 'Activities of Daily Living' assessment and training.

**Special Requirement** Acoustics: Acoustic privacy is required.

Body Protected Electrical Area

### Room Fabric and outline specifications

### Remarks

1025	Floor finish	Vinyl, non slip	Studded	Seamless, coved	tiles also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	tiles also acceptable
3000	Wall finish	Paint	Acrylic, washable		
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 dado	to bath & basin areas, tiles also acceptable
3070	Wall finish	Vinyl	Prefinished	Wall vinyl full height	to shower area, tiles also acceptable
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900mm AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9001	Doors	Solid Core	Paint	Single leaf	910mm clear opening, privacy latch

### Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
1000	Furniture/ Fitting	Bench seat	1	1	
3400	Metalwork	Coat hook	1	2	1 at 1000H
4800	Metalwork	Curtain track, shower	1	1	
6152	Furniture/ Fitting	Dispenser: disposable glove	2	1	near entry
6154	Furniture/ Fitting	Dispenser: paper towel	2	1	to basin
6156	Furniture/ Fitting	Dispenser: soap	2	1	to basin
8400	Metalwork	Grab rail - WC	1	2	
8450	Metalwork	Grab rail - Shower	1	1	
8500	Metalwork	Grab rail - WC, hinged	1	1	optional
9200	Metalwork	Hook, for catheter bag	1	2	optional
10800	Metalwork	IV hook	1	2	optional
13700	Metalwork	Mirror	1	1	above basin
13800	Metalwork	Mirror, full length	1	1	dressing
19910	Furniture/ Fitting	Shelf - vanity	1	1	
20650	Metalwork	Soap/ shampoo holder	1	2	
23700	Metalwork	Towel rail	1	1	

### Fixtures, Equipment and associated services

# Design Guidelines for Hospitals and Day Procedure Centres

## Standard Components Room Data Sheets

Room Name **ADL Bathroom**

Room Code **ADLB**

FFE ID	Description	Grp	Quantit	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
3050	Basin : hand, disabled	1	1	___	yes	___	yes	yes	yes	___	___	
3200	Bath: patient	1	1	___	yes	___	yes	yes	yes	___	___	
47400	Shower: hand-held	1	1	___	yes	___	yes	yes	yes	___	___	Short lever taps
47400	Shower: hand-held	1	1	___	yes	___	yes	yes	yes	___	___	low level over bath
55650	Toilet suite : disabled use	1	1	___	yes	___	___	yes	yes	___	___	

### Services

Service ID	Service Category	Description	Quantity	Remarks
4033	Hydraulics	Floor drain		
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
5019	HVAC	Exhaust		
6000	Lighting	General		
8000	Nurse Call	Patient / Nurse call	3	+ indicator button & light
8010	Nurse Call	Nurse assist call	3	+ indicator button & light
8080	Nurse Call	Emergency call	1	+ indicator button & light
9000	Power	GPO: Single	2	
9015	Power	GPO: Cleaner	1	
9040	Power	Body protected		