

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name **ADL Laundry**

Room Code **ADLL**

Area M2 **8**

Description Special Requirement

Domestic style laundry for patient Activities of Daily Living (ADL) assessment and training, wheelchair accessible.

Body Protected electrical area

Room Fabric and outline specifications

Remarks

1020	Floor finish	Vinyl, non-slip	Safety	Seamless, coved	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	
3000	Wall finish	Paint	Acrylic, washable		
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 dado	tiles also acceptable
5021	Ceiling	Plasterboard	Paint, washable	Water resistant, flush set, suspended	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel	Optional, 910mm clear opening

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
1050	Furniture/ Fitting	Bench: laminate	1	1	with inset laundry tub
1505	Furniture/ Fitting	Cabinet - ironing board	1	1	lockable
4410	Furniture/ Fitting	Cupboard: under bench	1	1	under laundry sink
4460	Furniture/ Fitting	Cupboard: wall mounted	1	1	over bench
10650	Furniture/ Fitting	Ironing board	1	1	in cabinet
20000	Furniture/ Fitting	Shelving unit, adjustable	1	1	over bench

Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quantit	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
49400	Sink : laundry, single	1	1	___	yes	yes	___	___	yes	___	___	with overflow drain

Services

Service ID	Service Category	Description	Quantity	Remarks
4033	Hydraulics	Floor drain	1	
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
5019	HVAC	Exhaust		
6000	Lighting	General		
9001	Power	GPO: Double	2	
9015	Power	GPO: Cleaner	1	
9040	Power	Body protected		
9060	Power	Special: for equipment	2	dryer & washer