

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name Anaesthetic Induction Room

Room Code ANIN

Area M2 15

**Description
Special Requirement**

The Anaesthetic Room is for holding patients on mobile beds or trolleys prior to operative procedures at times when the Operating Room is not available. Local, regional or general anaesthesia may be administered in this area.

Acoustics: Acoustic privacy is required

Body Protected electrical area

Room Fabric and outline specifications

Remarks

Fitting ID	Category	Fitting	Grp	Quantity	Selection
1000	Floor finish	Vinyl Standard slip resistant		Seamless, covered	
2000	Skirting	Vinyl Prefinished		Floor vinyl covered, 150mmH	
3000	Wall finish	Paint Acrylic, washable			
3060	Wall finish	Vinyl Prefinished		Splashback	to basin, tiles also acceptable
4020	Wall protection	Composite Prefinished PVC		Crash rail at 900mm AFFL	Equal to Acrovyn
5010	Ceiling	Plasterboard Paint, washable		Flush set, suspended	
6015	Cornice	Plasterboard Paint		Flush covered between wall & ceiling	
7010	Observation	Glass Clear		Through door/s	with covers
8010	Door protection	Composite Prefinished PVC		Protection plate to 900mm AFFL	Equal to Acrovyn
8040	Door protection	Composite Prefinished PVC		To door frame	Equal to Acrovyn
9013	Doors	Solid Core Paint		1 1/2 leaf, observation panel	1500mm clear opening

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
1050	Furniture/ Fitting	Bench: laminate	1	1	open under part
1465	Furniture/ Fitting	Bracket: suction bottle	2	2	on equipment rail
4380	Furniture/ Fitting	Cupboard: wall mount, glass front	1	1	over bench, lockable
4410	Furniture/ Fitting	Cupboard: under bench	1	1	
4430	Furniture/ Fitting	Cupboard: drawer unit	1	1	under bench
6152	Furniture/ Fitting	Dispenser: disposable glove	2	1	
6154	Furniture/ Fitting	Dispenser: paper towel	2	1	to basin
6156	Furniture/ Fitting	Dispenser: soap	2	1	to basin
6158	Furniture/ Fitting	Dispenser: soap antiseptic	2	1	to basin
7300	Metalwork	Equipment rail	1	1	under services panel
12900	Metalwork	Louvered panel, for storage-bins	1	3	457mmx457mm, over bench

Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quantit	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
3100	Basin : scrub - large	1	1	___	yes	___	yes	yes	yes	___	___	Type A
9750	Clock : slave, analogue	1	1	yes	___	___	___	___	___	___	___	
32150	Light : procedure- ceiling	1	1	yes	___	___	___	___	___	___	___	small

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name **Anaesthetic Induction Room**

Room Code **ANIN**

Services

Service ID	Service Category	Description	Quantity	Remarks
1006	Communications	Voice / Data outlet - double	2	1 - patient services panel
5005	HVAC	Air conditioning - special		Positive pressure, filtered
6001	Lighting	General : colour corrected		variable light level
6055	Lighting	Special: task light- built in		under O/H cupboards
7000	Medical Gases	O2	2	services panel
7010	Medical Gases	N2O	1	services panel (optional)
7020	Medical Gases	Medical Air	1	services panel (optional)
7040	Medical Gases	Suction	1	services panel
7070	Medical Gases	Scavenging	1	services panel (optional)
8010	Nurse Call	Nurse assist call	1	+ indicator button & light
8080	Nurse Call	Emergency call	1	+ indicator button & light
9001	Power	GPO: Double	6	patient services panel
9001	Power	GPO: Double	3	to walls (1 for fridge)
9010	Power	GPO: Single - emergency power	2	patient services panel
9010	Power	GPO: Single - emergency power	4	to bench
9010	Power	GPO: Single - emergency power	1	monitor - optional
9015	Power	GPO: Cleaner	1	
9040	Power	Body protected		
9060	Power	Special: for equipment	2	clock, light
11000	Services Panels	Wall panel		recessed