

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name **Anteroom**

Room Code **ANRM**

Area M2 **8**

Description Special Requirement

Anteroom or airlock associated with an Isolation room for maintenance of air pressurisation and for staff and visitors to change and dispose of protective gear used on entering or exit; a staff handwashing basin will be located within the room; glazing is recommended for patient visibility.
Pressurisation - negative or positive depending on type of Isolation room

Body Protected electrical area

Room Fabric and outline specifications

Remarks

1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	tiles also acceptable
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
7030	Observation	Alum/ glass	Powdercoat	Internal window, door height	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900mm AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9011	Doors	Solid Core	Paint	1 1/2 leaf, half glazed	1400mm clear opening

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
3400	Metalwork	Coat hook	1	2	
6152	Furniture/ Fitting	Dispenser: disposable glove	2	1	
6154	Furniture/ Fitting	Dispenser: paper towel	2	1	to basin
6156	Furniture/ Fitting	Dispenser: soap	2	1	to basin
6158	Furniture/ Fitting	Dispenser: soap antiseptic	2	1	to basin
20000	Furniture/ Fitting	Shelving unit, adjustable	1	1	for gowns

Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quantit	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
2800	Basin: handwash - medium	1	1	___	yes	___	yes	yes	yes	___	___	Type B

Services

Service ID	Service Category	Description	Quantity	Remarks
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
6000	Lighting	General		
9015	Power	GPO: Cleaner	1	
9040	Power	Body protected		