

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name Bathroom

Room Code BATH

Area M2 10

Description Special Requirement

The bathroom provides for assisted bathing of patients, patient dressing, undressing, grooming and handwashing. It is also used for bathing of patients for treatment or aromatherapy. Facilities include an island bath, toilet, and handbasin; a separate shower within the room is optional. A low height adjustable shower is required over the bath. Hydraulic lift baths may be considered for Occupational Health & Safety purposes. If the Bathroom is for use by children, the height, scale and type of fittings and fixtures should be suitable.

The Bathroom should allow for independent disabled access as well as the manoeuvring of a patient on a lifting device or shower bed. Space may be required to enable transfer of a patient to the bath from both sides. Placement of the toilet should allow assistance from both sides. The shower area must not have a raised hob. The entrance to the bathroom is to be flush with the adjoining corridor.

Acoustics: Sound attenuation level - Medium. Acoustic privacy required.

Body Protected electrical area

Room Fabric and outline specifications

Remarks

1025	Floor finish	Vinyl, non slip	Studded	Seamless, coved	tiles also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	tiles also acceptable
3000	Wall finish	Paint	Acrylic, washable		
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 dado	to bath & basin areas, tiles also acceptable
3070	Wall finish	Vinyl	Prefinished	Wall vinyl full height	to shower area, tiles also acceptable
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900mm AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9010	Doors	Solid Core	Paint	1 1/2 leaf	1350mm clear opening, privacy latch

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
1000	Furniture/ Fitting	Bench seat	1	1	
3400	Metalwork	Coat hook	1	2	1 at 1000H
4800	Metalwork	Curtain track, shower	1	1	
6152	Furniture/ Fitting	Dispenser: disposable glove	2	1	near entry
6154	Furniture/ Fitting	Dispenser: paper towel	2	1	to basin
6156	Furniture/ Fitting	Dispenser: soap	2	1	to basin
8400	Metalwork	Grab rail - WC	1	2	
8450	Metalwork	Grab rail - Shower	1	1	

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name **Bathroom**

Room Code BATH

Fitting ID	Category	Fitting	Grp	Quantity	Selection
8500	Metalwork	Grab rail - WC, hinged	1	1	optional
9200	Metalwork	Hook, for catheter bag	1	2	optional
10800	Metalwork	IV hook	1	2	optional
13700	Metalwork	Mirror	1	1	above basin
13800	Metalwork	Mirror, full length	1	1	dressing, optional
19910	Furniture/ Fitting	Shelf - vanity	1	1	
20650	Metalwork	Soap/ shampoo holder	1	2	
23700	Metalwork	Towel rail	1	1	

Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quantit	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
3050	Basin : hand, disabled	1	1	___	yes	___	yes	yes	yes	___	___	
3200	Bath: patient	1	1	___	yes	___	yes	yes	yes	___	___	island bath
47400	Shower: hand-held	1	1	___	yes	___	yes	yes	yes	___	___	low level over bath
47400	Shower: hand-held	1	1	___	yes	___	yes	yes	yes	___	___	Short lever taps
55650	Toilet suite : disabled use	1	1	___	yes	___	___	yes	yes	___	___	

Services

Service ID	Service Category	Description	Quantity	Remarks
4033	Hydraulics	Floor drain		
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
5019	HVAC	Exhaust		
6000	Lighting	General		
8000	Nurse Call	Patient / Nurse call	3	+ indicator button & light
8010	Nurse Call	Nurse assist call	3	+ indicator button & light
8080	Nurse Call	Emergency call	1	+ indicator button & light
9000	Power	GPO: Single	2	
9015	Power	GPO: Cleaner	1	
9040	Power	Body protected		