

# Design Guidelines for Hospitals and Day Procedure Centres

## Standard Components Room Data Sheets

Room Name Bay - Flowers

Room Code BFLW

Area M2 2

**Description** Area with bench and sink for use by staff and volunteers to maintain patients' flowers. If the area is to be enclosed in a room - add 3m2.

**Special Requirement**

Acoustics: Acoustic privacy required

### Room Fabric and outline specifications

### Remarks

1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	tiles also acceptable
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900mm AFFL	As required, Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	As required, Equal to Acrovyn
9001	Doors	Solid Core	Paint	Single leaf	850 clear opening, lock set

### Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
1050	Furniture/ Fitting	Bench: laminate	1	1	open under part for bin
4410	Furniture/ Fitting	Cupboard: under bench	1	1	adjustable shelf
4460	Furniture/ Fitting	Cupboard: wall mounted	1	1	over bench
6154	Furniture/ Fitting	Dispenser: paper towel	2	1	to sink
6156	Furniture/ Fitting	Dispenser: soap	2	1	to sink
20000	Furniture/ Fitting	Shelving unit, adjustable	1	1	above bench for storing vases

### Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quantity	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
47890	Sink & drainer: 930mmW	1	1	___	yes	___	yes	yes	yes	___	___	short lever taps

### Services

Service ID	Service Category	Description	Quantity	Remarks
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
6000	Lighting	General		
9000	Power	GPO: Single	1	Above bench