

# Design Guidelines for Hospitals and Day Procedure Centres

## Standard Components Room Data Sheets

Room Name Bay - Handwashing

Room Code BHWS

Area M2 1

### Description Special Requirement

A recessed bay off the corridor with handwashing facilities for staff to cleanse their hands before and after every patient contact.

Variations:

Type A - Clinical Scrub basin (Large) with wall mounted, elbow action lever taps - for surgical scrub

Type B - Handbasin (Medium) with basin mounted elbow action lever taps - for procedural handwashing

Type C - Handbasin (Small to Medium) with basin mounted wrist action lever taps - for general handwashing

### Room Fabric and outline specifications

### Remarks

1000	Floor finish	Vinyl	Standard slip resistant	Seamless, covered	
2000	Skirting	Vinyl	Prefinished	Floor vinyl covered, 150mmH	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	tiles also acceptable
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900H	As required, equal to Acrovyn
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	

### Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
6152	Furniture/ Fitting	Dispenser: disposable glove	2	1	optional
6153	Furniture/ Fitting	Dispenser: moisturiser	2	1	optional
6154	Furniture/ Fitting	Dispenser: paper towel	2	1	
6156	Furniture/ Fitting	Dispenser: soap	2	1	
6158	Furniture/ Fitting	Dispenser: soap antiseptic	2	1	

### Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quantity	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
2800	Basin: handwash - medium	1	1	___	yes	___	yes	yes	yes	___	___	or Type A / Type C

### Services

Service ID	Service Category	Description	Quantity	Remarks
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
6000	Lighting	General		