Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name	Bay - Mobile Equipment	Room Code BMEQ		
Area M2	4			
Description Special Requirement	which may include wheelchairs, mobile scales, co	rage bay for one or more items of mobile equipment in frequent use nclude wheelchairs, mobile scales, commode chairs, chair scales, rs, patient lifting devices, other equipment or X-ray equipment. Add 2 equipment is to be stored.		
		I Design Requirements: The Bay should be deep enough to ensure nent stored does not impede corridor circulation; minimum depth 1000mm.		

Room I	Remarks				
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	
3000	Wall finish	Paint	Acrylic, washable		
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900mm AFFL	Equal to Acrovyn
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900H	As required; Equal to Acrovyn
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	

Fittings and Furniture

Fixtures, Equipment and associated services

Services

Service ID	Service Category	Description	Quantity	Remarks
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
6000	Lighting	General		
9000	Power	GPO: Single	2	For recharging of electrical equipment



