

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name Bay - Resuscitation Trolley

Room Code BREST

Area M2 2

Description Special Requirement

A recessed bay to provide supervised holding of the resuscitation trolley and equipment.

Special Design Requirements: The Bay shall be a minimum of 600mm deep.

Room Fabric and outline specifications

Remarks

1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	
3000	Wall finish	Paint	Acrylic, washable		
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900mm AFFL	Equal to Acrovyn
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900H	As required; Equal to Acrovyn
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
4460	Furniture/ Fitting	Cupboard: wall mounted	1	1	over trolley, optional

Fixtures, Equipment and associated services

Services

Service ID	Service Category	Description	Quantity	Remarks
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
6000	Lighting	General		
9011	Power	GPO: Emergency power - double	1	for recharging emergency equipment