Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name	Birthing Room - LDR	Room Code BIR
Area M2	28	
Descriptio Special Requirement		
	Acoustics: Sound attenuation level high: Acoustics	stic privacy required

Body Protected electrical area

Room Fabric and outline specifications

		ne opeenieu			
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	to basin
3092	Wall protection	MDF	Laminate	Bed protection wall panel	
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900H	
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended	
6010	Cornice	Plasterboard	Paint	90mm to match ceiling finish	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900mm AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9010	Doors	Solid Core	Paint	1 1/2 leaf	1350mm clear opening

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
1050	Furniture/ Fitting	Bench: laminate	1	1	
1360	Furniture/ Fitting	Boot rack	2	1	optional
1470	Metalwork	Bracket: sharps	2	1	
4330	Furniture/ Fitting	Cupboard: wardrobe	1	1	
4391	Furniture/ Fitting	Cupboard: special	1	1	to conceal services
4460	Furniture/ Fitting	Cupboard: wall mounted	1	1	over bench
4600	Metalwork	Curtain track, bed	1	1	
4900	Metalwork	Curtain track, window	1	1	
6152	Furniture/ Fitting	Dispenser: disposable glove	2	1	
6154	Furniture/ Fitting	Dispenser: paper towel	2	1	
6156	Furniture/ Fitting	Dispenser: soap	2	1	to basin
6158	Furniture/ Fitting	Dispenser: soap antiseptic	2	1	to basin
13800	Metalwork	Mirror, full length	1	1	may be enclosed with doors
19800	Furniture/ Fitting	Shelf, laminate	1	1	near basin

Fixtures, Equipment and associated services





Remarks

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name

Birthing Room - LDR

FFE ID Selection Description HtW WmW Tap Dns Gas Stm Grp Quantit Ele CdW yes 3100 Basin : scrub - large 1 1 yes yes yes 32150 Light : procedure- ceiling 1 1 or may use portable light yes

Services

Service ID	Service Category	Description	Quantity	Remarks
1006	Communications	Voice / Data outlet - double	2	
1090	Communications	TV: MATV	1	
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
6001	Lighting	General : colour corrected		
6050	Lighting	Special: reading		
6110	Lighting	Dimmable- down lights		
7000	Medical Gases	O2	2	1-mother; 1-baby
7010	Medical Gases	N2O	1	1-mother
7020	Medical Gases	Medical Air	2	1-mother; 1-baby, optional
7040	Medical Gases	Suction	2	1-mother; 1 baby
7070	Medical Gases	Scavenging	1	mother - for N2O
8000	Nurse Call	Patient / Nurse call	1	+ indicator button & light
8005	Nurse Call	Patient call handset	1	call button on the handset
8010	Nurse Call	Nurse assist call	1	+ indicator button & light
8080	Nurse Call	Emergency call	1	+ indicator button & light
9000	Power	GPO: Single	4	2-mother; 2-baby
9001	Power	GPO: Double	3	bench & walls, optional
9010	Power	GPO: Single - emergency power	4	2-mother; 2- baby
9040	Power	Body protected		
9060	Power	Special: for equipment	2	Procedure light, TV





Room Code BIR