

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name **Change - Staff**

Room Code CHST

Area M2 8

Description Special Requirement

Staff Change areas are provided for staff to change into appropriate work clothing or gowns, to store their street clothing and to perform personal ablutions. Change Rooms should be divided into Male and Female areas on a proportional basis. Secured, staff only access to Change Rooms is required.

Acoustics: Sound attenuation level - medium; acoustic privacy required.

Room Fabric and outline specifications

Remarks

1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	
3000	Wall finish	Paint	Acrylic, washable		
3070	Wall finish	Vinyl	Prefinished	Wall vinyl full height	to wet areas, tiles also acceptable
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
8000	Door protection	Vinyl	Prefinished	Kickplate, 300mm high	Equal to Acrovyn
9001	Doors	Solid Core	Paint	Single leaf	850mm clear; Secure staff only access

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
530	Furniture/ Fitting	Basin vanity top	1	1	
1000	Furniture/ Fitting	Bench seat	1	1	To shower cubicle
3350	Furniture/ Fitting	Clock - battery operated	1	1	
3400	Metalwork	Coat hook	1	2	WC / Shower cubicles
4800	Metalwork	Curtain track, shower	1	1	
6154	Furniture/ Fitting	Dispenser: paper towel	2	1	to basin
6156	Furniture/ Fitting	Dispenser: soap	2	1	to basin
6160	Furniture/ Fitting	Dispenser: toilet paper	2	1	
13700	Metalwork	Mirror	1	1	above basin
13700	Metalwork	Mirror	1	1	Full height
20055	Furniture/ Fitting	Shower partitions	1	1	
20650	Metalwork	Soap/ shampoo holder	1	1	to shower cubicle
23610	Furniture/ Fitting	Toilet partitions	1	1	

Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quant	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
3120	Basin: vanity	1	3	___	yes	___	yes	yes	yes	___	___	
47500	Shower with fixed rose	1	1	___	yes	___	yes	yes	yes	___	___	
55600	Toilet suite: standard	1	3	___	yes	___	___	yes	yes	___	___	

Services

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name

Change - Staff

Room Code CHST

Service ID	Service Category	Description	Quantity	Remarks
4033	Hydraulics	Floor drain		
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
6000	Lighting	General		
9001	Power	GPO: Double	1	