

# Design Guidelines for Hospitals and Day Procedure Centres

## Standard Components Room Data Sheets

Room Name Consult Room

Room Code CONS

Area M2 12

### Description Special Requirement

The Consult Room will provide for private consultation and examination of patients with or without support persons present. A second egress door may be required for staff safety and security.

Acoustics: Sound attenuation level - high; Acoustic privacy essential.

Body Protected electrical area

### Room Fabric and outline specifications

### Remarks

1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	Carpet also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	or vinyl featheredge skirting over carpet
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	tiles also acceptable
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900mm AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9001	Doors	Solid Core	Paint	Single leaf	910mm clear opening, latch se, lockable

### Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
1470	Metalwork	Bracket: sharps	2	1	
3400	Metalwork	Coat hook	1	2	
4600	Metalwork	Curtain track, bed	1	1	to exam couch
6152	Furniture/ Fitting	Dispenser: disposable glove	2	1	
6153	Furniture/ Fitting	Dispenser: moisturiser	2	1	to hand basin
6154	Furniture/ Fitting	Dispenser: paper towel	2	1	to hand basin
6156	Furniture/ Fitting	Dispenser: soap	2	1	to hand basin
6158	Furniture/ Fitting	Dispenser: soap antiseptic	2	1	to hand basin
13700	Metalwork	Mirror	1	1	for patient changing, optional
17360	Furniture/ Fitting	Pinboard, fabric covered	1	1	over desk, optional
20000	Furniture/ Fitting	Shelving unit, adjustable	1	1	over desk, optional

### Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quantit	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
2800	Basin: handwash - medium	1	1	___	yes	___	yes	yes	yes	___	___	Type B
31701	Light: examination, wall mount	1	1	yes	___	___	___	___	___	___	___	or ceiling mounted, optional
68700	Xray viewer, 2 screen	1	1	yes	___	___	___	___	___	___	___	

### Services

## Design Guidelines for Hospitals and Day Procedure Centres

### Standard Components Room Data Sheets

Room Name **Consult Room**

Room Code CONS

Service ID	Service Category	Description	Quantity	Remarks
1006	Communications	Voice / Data outlet - double	2	
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
6000	Lighting	General		
8000	Nurse Call	Patient / Nurse call	1	+ indicator button & light
8010	Nurse Call	Nurse assist call	1	+ indicator button & light
8080	Nurse Call	Emergency call	1	+ indicator button & light
9000	Power	GPO: Single	6	
9015	Power	GPO: Cleaner	1	
9040	Power	Body protected		
9060	Power	Special: for equipment	2	XRV, exam light