Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name	Ensuite - Mental Health	Room Code ENS-E
Area M2	5	
Description Special Requirement	The Ensuite - Mental Health will provide a shower, to mental health patients. The Ensuite will be lockable privacy latch on the inside.	,
	Acoustics: Sound attenuation level high; Acoustic p	rivacy required
	Body Protected electrical area	
	Additional Design Considerations: - Two floor wastes will be required - Fittings are to have a breaking strain of not more t - Grab rails and shower must not provide points for - Cisterns should be concealed - All glazing in the room including mirror to be unbreak	ligature

Room Fabric and outline specifications

		•			
1025	Floor finish	Vinyl, non slip	Studded	Seamless, coved	tiles also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	or tiles for a tiled floor
3000	Wall finish	Paint	Acrylic, washable		
3070	Wall finish	Vinyl	Prefinished	Wall vinyl full height	to wet areas; tiles also acceptable
5021	Ceiling	Plasterboard	Paint, washable	Water resistant, flush set, suspended	
6010	Cornice	Plasterboard	Paint	90mm to match ceiling finish	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900mm AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9001	Doors	Solid Core	Paint	Single leaf	910 clear outward opening, privacy latch

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
3400	Metalwork	Coat hook	1	2	collapsible
4800	Metalwork	Curtain track, shower	1	1	plastic, ceiling mounted/ recessed
8400	Metalwork	Grab rail - WC	1	1	vertical
8450	Metalwork	Grab rail - Shower	1	1	vertical
13730	Furniture/ Fitting	Mirror, acrylic	1	1	
16700	Metalwork	Paper towel dispenser	2	1	
19910	Furniture/ Fitting	Shelf - vanity	1	1	recessed
20300	Metalwork	Soap dispenser	2	1	
20650	Metalwork	Soap/ shampoo holder	1	1	recessed
23600	Metalwork	Toilet paper holder	2	1	

Fixtures, Equipment and associated services





Remarks

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name

Ensuite - Mental Health

Room Code ENS-E

FFE ID	Description	Grp	Quantit	Ele	CdW	HtW	WmW	Тар	Dns	Gas	Stm	Selection
2800	Basin: handwash - medium	1	1		yes		yes	yes	yes			
47550	Shower: corrective services	1	1		yes		yes	yes	yes			
55605	Toilet suite : patient	1	1		yes			yes	yes			concealed cisterns

Services

Service ID	Service Category	Description	Quantity	Remarks
4033	Hydraulics	Floor drain	2	
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
5019	HVAC	Exhaust		Refer to Part E Building Services
6000	Lighting	General		
8000	Nurse Call	Patient / Nurse call	2	+ indicator button & light
9000	Power	GPO: Single	1	
9040	Power	Body protected		



