

# Design Guidelines for Hospitals and Day Procedure Centres

## Standard Components Room Data Sheets

Room Name **Formula Room**

Room Code **FORM**

Area M2 **9**

### Description Special Requirement

The Formula Room provides space for the preparation, distribution and storage of baby feeds. Pre-packaged feeds will also be stored in this area.  
The room will provide facilities for washing, sterilisation and storage of baby bottles, teats and equipment, preparation of baby formulas, refrigerated storage of baby feeds and demonstration of formula preparation to mothers.

Acoustics: Acoustic privacy required

### Room Fabric and outline specifications

### Remarks

1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	tiles also acceptable
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900mm AFFL	equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	equal to Acrovyn
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel	910 mm clear opening

### Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
1050	Furniture/ Fitting	Bench: laminate	1	1	with inset sink
4410	Furniture/ Fitting	Cupboard: under bench	1	1	
4430	Furniture/ Fitting	Cupboard: drawer unit	1	1	
4460	Furniture/ Fitting	Cupboard: wall mounted	1	1	over bench
6154	Furniture/ Fitting	Dispenser: paper towel	2	1	to sink
6156	Furniture/ Fitting	Dispenser: soap	2	1	to sink
19990	Furniture/ Fitting	Shelving unit - microwave	1	1	over bench

### Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quant	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
5000	Boiling water unit	1	1	yes	yes	___	___	yes	yes	___	___	
47890	Sink & drainer: 930mmW	1	1	___	yes	___	yes	yes	yes	___	___	

### Services

Service ID	Service Category	Description	Quantity	Remarks
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
6000	Lighting	General		
9000	Power	GPO: Single	3	
9060	Power	Special: for equipment	2	BWU, fridge