

# Design Guidelines for Hospitals and Day Procedure Centres

## Standard Components Room Data Sheets

Room Name **Gymnasium**

Room Code **GYAH**

Area M2 40

### Description Special Requirement

The Gymnasium provides for patient evaluation, rehabilitation exercise activities, therapy and ambulation training. An external outlook is desirable.

Acoustics: Acoustic privacy required.

Body protected electrical area

### Room Fabric and outline specifications

### Remarks

|      |                 |              |                         |                                |                       |
|------|-----------------|--------------|-------------------------|--------------------------------|-----------------------|
| 1000 | Floor finish    | Vinyl        | Standard slip resistant | Seamless, coved                |                       |
| 2000 | Skirting        | Vinyl        | Prefinished             | Floor vinyl coved, 150mmH      |                       |
| 3000 | Wall finish     | Paint        | Acrylic, washable       |                                |                       |
| 5030 | Ceiling         | Plasterboard | Prefinished             | Drop-in tiles, 600x1200        |                       |
| 6030 | Cornice         | Aluminium    | Powdercoat              | 24mm shadow angle              |                       |
| 7001 | Windows         |              |                         |                                | desirable             |
| 8010 | Door protection | Composite    | Prefinished PVC         | Protection plate to 900mm AFFL | Equal to Acrovyn      |
| 8040 | Door protection | Composite    | Prefinished PVC         | To door frame                  | Equal to Acrovyn      |
| 9023 | Doors           | Solid Core   | Paint                   | Double leaf, observation panel | 1500 mm clear opening |

### Fittings and Furniture

| Fitting ID | Category           | Fitting                            | Grp | Quantity | Selection             |
|------------|--------------------|------------------------------------|-----|----------|-----------------------|
| 1050       | Furniture/ Fitting | Bench: laminate                    | 1   | 1        | optional              |
| 3350       | Furniture/ Fitting | Clock - battery operated           | 1   | 1        |                       |
| 4410       | Furniture/ Fitting | Cupboard: under bench              | 1   | 1        | optional              |
| 4430       | Furniture/ Fitting | Cupboard: drawer unit              | 1   | 1        | under bench, optional |
| 4460       | Furniture/ Fitting | Cupboard: wall mounted             | 1   | 1        | over bench, optional  |
| 4600       | Metalwork          | Curtain track, bed                 | 1   | 2        | to plinths            |
| 6154       | Furniture/ Fitting | Dispenser: paper towel             | 2   | 2        | to basin & sink       |
| 6156       | Furniture/ Fitting | Dispenser: soap                    | 2   | 2        | to basin & sink       |
| 13645      | Metalwork          | Metal mesh, framed - ceiling mount | 1   | 2        | to plinths            |
| 13646      | Metalwork          | Metal mesh, framed - wall mount    | 1   | 2        | to plinths            |

### Fixtures, Equipment and associated services

| FFE ID | Description              | Grp | Quant | Ele | CdW | HtW | WmW | Tap | Dns | Gas | Stm | Selection   |
|--------|--------------------------|-----|-------|-----|-----|-----|-----|-----|-----|-----|-----|-------------|
| 2800   | Basin: handwash - medium | 1   | 1     | ___ | yes | ___ | yes | yes | yes | ___ | ___ | Type B or C |
| 47890  | Sink & drainer: 930mmW   | 1   | 1     | ___ | yes | ___ | yes | yes | yes | ___ | ___ | optional    |

### Services

| Service ID | Service Category | Description                            | Quantity | Remarks                           |
|------------|------------------|--|----------|-----------------------------------|
| 1006       | Communications   | Voice / Data outlet - double           | 1        |                                   |
| 5000       | HVAC             | Heating, Ventilation & Airconditioning |          | Refer to Part E Building Services |
| 6000       | Lighting         | General                                |          |                                   |
| 8000       | Nurse Call       | Patient / Nurse call                   | 2        | + indicator button & light        |

## Design Guidelines for Hospitals and Day Procedure Centres

### Standard Components Room Data Sheets

Room Name **Gymnasium**

Room Code GYAH

| Service ID | Service Category | Description          | Quantity | Remarks                    |
|------------|------------------|----------------------|----------|----------------------------|
| 8005       | Nurse Call       | Patient call handset | 2        | call button on the handset |
| 8010       | Nurse Call       | Nurse assist call    | 1        | + indicator button & light |
| 8080       | Nurse Call       | Emergency call       | 1        | + indicator button & light |
| 9001       | Power            | GPO: Double          | 10       |                            |
| 9015       | Power            | GPO: Cleaner         | 1        |                            |
| 9040       | Power            | Body protected       |          |                            |