

# Design Guidelines for Hospitals and Day Procedure Centres

## Standard Components Room Data Sheets

**Room Name** Interview Room - Family/ Large

**Room Code** INTF

**Area M2** 12

### Description Special Requirement

A larger Interview Room to undertake confidential discussion and/ or counselling between staff, patients and or family members where required. The Interview Room may also be used as a multipurpose room for small staff groups or discussions. An external outlook is desirable.

Acoustics: Sound attenuation level - high; Acoustic privacy required.

Additional Design Considerations:

- A second egress door may be required for staff safety and security

### Room Fabric and outline specifications

### Remarks

1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom; 48 oz.	Vinyl also acceptable
2010	Skirting	Vinyl	Prefinished	Feather edged, 150mmH	or floor vinyl coved skirting
3000	Wall finish	Paint	Acrylic, washable		
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200	
7001	Windows				Desirable
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900mm AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel	910mm clear opening, lock set

### Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
17360	Furniture/ Fitting	Pinboard, fabric covered	1	1	optional
17385	Furniture/ Fitting	Pinboard/ Whiteboard	1	1	optional

### Fixtures, Equipment and associated services

#### Services

Service ID	Service Category	Description	Quantity	Remarks
1006	Communications	Voice / Data outlet - double	1	
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
6000	Lighting	General		
6046	Lighting	Indirect lighting		optional
9000	Power	GPO: Single	4	
9015	Power	GPO: Cleaner	1	
10005	Security	Duress alarm	1	