Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name	Interview Room	Room Code INT	
Area M2	9		
Description Special Requirement	patients and or family members where require	te confidential discussion and/ or counselling between staff, hily members where required. The Interview Room may also be bose room for small staff groups or discussions. An external e.	
	Acoustics: Sound attenuation level - high; Acoustics:	oustic privacy required.	

Room	Fabric and ou	Remarks			
1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom; 48 oz.	vinyl also acceptable
2010	Skirting	Vinyl	Prefinished	Feather edged, 150mmH	or floor vinyl coved skirting
3000	Wall finish	Paint	Acrylic, washable		
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
7001	Windows				Desirable
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel	910mm clear opening

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
3400	Metalwork	Coat hook	1	2	
24400	Metalwork	Whiteboard	1	1	900 x 900, optional

Fixtures, Equipment and associated services

Services

Service ID	Service Category	Description	Quantity	Remarks
1006	Communications	Voice / Data outlet - double	1	
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
6000	Lighting	General		
6046	Lighting	Indirect lighting		optional
9000	Power	GPO: Single	4	
9015	Power	GPO: Cleaner	1	
10005	Security	Duress alarm	1	



