

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name Neonatal Bay - General Care

Room Code NBGC

Area M2 5

Description Special Requirement

A single bay for the care of well babies away from their mother's bed area which may include treatments such as phototherapy. A staff handwash basin should be provided for each four Neonatal Bays - General Care. An external outlook is required.

Acoustics: Sound attenuation level - high; Acoustic privacy is required to perimeter walls

Body Protected electrical area

Room Fabric and outline specifications

Remarks

1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH
3000	Wall finish	Paint	Acrylic, washable	
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended
6010	Cornice	Plasterboard	Paint	90mm to match ceiling finish
7001	Windows			

Essential

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
1465	Furniture/ Fitting	Bracket: suction bottle	2	1	shared between 2 bays

Fixtures, Equipment and associated services

Services

Service ID	Service Category	Description	Quantity	Remarks
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
6001	Lighting	General : colour corrected		
6005	Lighting	Dimmable		variable lighting level
7000	Medical Gases	O2	1	shared between 4 bays
7020	Medical Gases	Medical Air	1	shared between 4 bays
7040	Medical Gases	Suction	1	shared between 4 bays
8010	Nurse Call	Nurse assist call	1	shared between 4 bays
8080	Nurse Call	Emergency call	1	shared between 4 bays
9000	Power	GPO: Single	2	shared between 2 bays
9015	Power	GPO: Cleaner	1	
9040	Power	Body protected		