

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name Neonatal Bay - Special Care

Room Code NBSC

Area M2 10

Description Special Requirement

A single bay for neonates requiring Special Care nursing and medical treatment. The Bay will include provisions for charting and storage. A staff handwash basin (Type A) should be provided within close access of each Bay. An external outlook is required.

Acoustics: Sound attenuation level - high; Acoustic privacy is required to perimeter walls

Cardiac Protected electrical area

Room Fabric and outline specifications

Remarks

| | | | | |
|------|-----------------|--------------|-------------------------|------------------------------|
| 1000 | Floor finish | Vinyl | Standard slip resistant | Seamless, covered |
| 2000 | Skirting | Vinyl | Prefinished | Floor vinyl coved, 150mmH |
| 3000 | Wall finish | Paint | Acrylic, washable | |
| 3092 | Wall protection | MDF | Laminate | Bed protection wall panel |
| 5010 | Ceiling | Plasterboard | Paint, washable | Flush set, suspended |
| 6010 | Cornice | Plasterboard | Paint | 90mm to match ceiling finish |
| 7001 | Windows | | | |

Essential

Fittings and Furniture

| Fitting ID | Category | Fitting | Grp | Quantity | Selection |
|------------|--------------------|---------------------------|-----|----------|------------|
| 1050 | Furniture/ Fitting | Bench: laminate | 1 | 1 | |
| 1465 | Furniture/ Fitting | Bracket: suction bottle | 2 | 2 | |
| 4410 | Furniture/ Fitting | Cupboard: under bench | 1 | 1 | |
| 20000 | Furniture/ Fitting | Shelving unit, adjustable | 1 | 1 | over bench |

Fixtures, Equipment and associated services

| FFE ID | Description | Grp | Quantity | Ele | CdW | HtW | WmW | Tap | Dns | Gas | Stm | Selection |
|--------|------------------------------|-----|----------|-----|-----|-----|-----|-----|-----|-----|-----|-----------|
| 31700 | Light : examination, ceiling | 1 | 1 | yes | ___ | ___ | ___ | ___ | ___ | ___ | ___ | |

Services

| Service ID | Service Category | Description | Quantity | Remarks |
|------------|------------------|--|----------|-----------------------------------|
| 1006 | Communications | Voice / Data outlet - double | 1 | |
| 5000 | HVAC | Heating, Ventilation & Airconditioning | | Refer to Part E Building Services |
| 6001 | Lighting | General : colour corrected | | |
| 6005 | Lighting | Dimmable | | variable lighting level |
| 7000 | Medical Gases | O2 | 2 | |
| 7020 | Medical Gases | Medical Air | 2 | |
| 7040 | Medical Gases | Suction | 2 | |
| 8010 | Nurse Call | Nurse assist call | 1 | |
| 8080 | Nurse Call | Emergency call | 1 | |
| 9010 | Power | GPO: Single - emergency power | 8 | |
| 9015 | Power | GPO: Cleaner | 1 | |

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name **Neonatal Bay - Special Care**

Room Code NBSC

| Service ID | Service Category | Description | Quantity | Remarks |
|------------|------------------|------------------------|----------|------------|
| 9030 | Power | Cardiac Protected | | |
| 9060 | Power | Special: for equipment | 1 | exam light |