

# Design Guidelines for Hospitals and Day Procedure Centres

## Standard Components Room Data Sheets

Room Name **Pantry**

Room Code **PTRY**

Area M2 **8**

### Description Special Requirement

The Pantry is for preparing and/ or heating refreshments, snacks and some meals for patients, washing some utensils, storing food and drink and disposing of food waste. It may also provide space for a meal collection trolley. If food rethermalisation trolleys are to be located in this room during meal times, up to an additional four m2 may be added to the total area.

### Room Fabric and outline specifications

### Remarks

1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	Full length of bench, tiles also acceptable
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900H	Equal to Acrovyn, as required
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900mm AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel	910 mm clear opening

### Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
1050	Furniture/ Fitting	Bench: laminate	1	1	with inset sink/drain
4410	Furniture/ Fitting	Cupboard: under bench	1	1	
4430	Furniture/ Fitting	Cupboard: drawer unit	1	1	under bench
4460	Furniture/ Fitting	Cupboard: wall mounted	1	1	above bench, adjustable shelf
6154	Furniture/ Fitting	Dispenser: paper towel	2	1	to sink
6156	Furniture/ Fitting	Dispenser: soap	2	1	to sink
19990	Furniture/ Fitting	Shelving unit - microwave	1	1	over bench, optional

### Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quantity	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
5000	Boiling water unit	1	1	yes	yes	___	___	yes	yes	___	___	optional
47890	Sink & drainer: 930mmW	1	1	___	yes	___	yes	yes	yes	___	___	lever taps

### Services

Service ID	Service Category	Description	Quantity	Remarks
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
6000	Lighting	General		
9000	Power	GPO: Single	1	above bench
9001	Power	GPO: Double	3	fridge; boiling water unit; m/wave