

# Design Guidelines for Hospitals and Day Procedure Centres

## Standard Components Room Data Sheets

Room Name **Plaster Room**

Room Code **PLST**

Area M2 14

### Description Special Requirement

The Plaster Room allows for the application of Plaster of Paris, or other splints, and for the closed reduction of displaced fractures or dislocations under sedative or regional anaesthesia.

Sound attenuation level - high; acoustic privacy required

Body protected electrical area

### Room Fabric and outline specifications

### Remarks

1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	tiles also acceptable
3092	Wall protection	MDF	Laminate	Bed protection wall panel	
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900mm AFFL	Equal to Acrovyn
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900mm AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9013	Doors	Solid Core	Paint	1 1/2 leaf, observation panel	1400mm clear opening, sliding cover to glazing

### Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
1010	Metalwork	Bench: stainless steel	1	1	with S/S sink
1465	Furniture/ Fitting	Bracket: suction bottle	2	1	
1470	Metalwork	Bracket: sharps	2	1	
4360	Furniture/ Fitting	Cupboard: door ht adj. shelves	1	1	lockable
4410	Furniture/ Fitting	Cupboard: under bench	1	1	adjustable shelf
4460	Furniture/ Fitting	Cupboard: wall mounted	1	1	over bench, adjustable shelf
6152	Furniture/ Fitting	Dispenser: disposable glove	2	1	to basin
6154	Furniture/ Fitting	Dispenser: paper towel	2	1	to basin
6156	Furniture/ Fitting	Dispenser: soap	2	1	to basin
6158	Furniture/ Fitting	Dispenser: soap antiseptic	2	1	to basin
12900	Metalwork	Louvered panel, for storage-bins	1	4	optional

### Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quantity	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
2800	Basin: handwash - medium	1	1	___	yes	___	yes	yes	yes	___	___	Type B
31700	Light : examination, ceiling	1	1	yes	___	___	___	___	___	___	___	
40300	Plaster trap	1	1	___	___	___	___	___	yes	___	___	under sink
47800	Sink, S/S: single in bench	1	1	___	yes	yes	___	yes	yes	___	___	

# Design Guidelines for Hospitals and Day Procedure Centres

## Standard Components Room Data Sheets

Room Name **Plaster Room**

Room Code **PLST**

FFE ID	Description	Grp	Quant	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
68700	Xray viewer, 2 screen	1	1	yes	___	___	___	___	___	___	___	

### Services

Service ID	Service Category	Description	Quantity	Remarks
1006	Communications	Voice / Data outlet - double	2	
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
6001	Lighting	General : colour corrected		
7000	Medical Gases	O2	1	
7010	Medical Gases	N2O	1	optional
7020	Medical Gases	Medical Air	1	optional
7040	Medical Gases	Suction	1	
7070	Medical Gases	Scavenging	1	if N2O provided
8000	Nurse Call	Patient / Nurse call	1	+ indicator button & light
8005	Nurse Call	Patient call handset	1	call button on the handset
8010	Nurse Call	Nurse assist call	1	+ indicator button & light
8080	Nurse Call	Emergency call	1	+ indicator button & light
9000	Power	GPO: Single	4	patient services panel
9001	Power	GPO: Double	3	to walls, bench
9010	Power	GPO: Single - emergency power	2	patient services panel
9015	Power	GPO: Cleaner	1	
9040	Power	Body protected		
9060	Power	Special: for equipment	3	XRV, fridge, exam light