

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name	Scrub Up / Gowning	Room Code	SCRB
Area M2	6		
Description	The Scrub-up Gowning room provides an enclosed area for pre-operative scrubbing and gowning. The room may be shared between Operating/ Procedure Rooms.		
Special Requirement	Acoustics: Sound attenuation level - medium; acoustic privacy required		
	Additional Design Considerations:		
	- A minimum of 800mm is required between scrub stations		
	- Taps to be non touch - automatically operated or foot operated		

Room Fabric and outline specifications					Remarks
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, covered	
1020	Floor finish	Vinyl, non-slip	Safety	Seamless, covered	to wet zone
2000	Skirting	Vinyl	Prefinished	Floor vinyl covered, 150mmH	
3010	Wall finish	Paint	Scrub resistant		
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 dado	
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900H	as required, Equal to Acrovyn
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended	
6015	Cornice	Plasterboard	Paint	Flush covered between wall & ceiling	
7010	Observation	Glass	Clear	Through door/s	with cover
7030	Observation	Alum/ glass	Powdercoat	Internal window, door height	to adjacent operating room desirable
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900mm AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel	910mm clear opening

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
1252	Furniture/ Fitting	Blind: Venetian integral	1	1	to internal windows if provided
6158	Furniture/ Fitting	Dispenser: soap antiseptic	2	2	
13800	Metalwork	Mirror, full length	1	1	
19810	Metalwork	Shelf, S/S, Over	1	1	over scrub trough

Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quantit	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
9700	Clock : analogue, wall	1	1	yes	___	___	___	___	___	___	___	
50000	Sink : scrub trough	1	1	___	yes	___	yes	yes	yes	___	___	auto/knee operated taps x 2

Services

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name **Scrub Up / Gowning**

Room Code **SCRB**

Service ID	Service Category	Description	Quantity	Remarks
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
6000	Lighting	General		