Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name

Seclusion Room

Room Code SECL

Area M2

14

Description Special Requirement

A Seclusion Room provides for the sole confinement of a distressed or agitated person requiring separation for short periods at any hour of the day or night on an involuntary basis. The Seclusion Room will be observable from the Staff Station. An external outlook is desirable.

Acoustics: Sound attenuation level high; Acoustic privacy is required

Additional Design Considerations:

- An internal observation window is required
- A second room egress door is required

Room I	Remarks				
1010	Floor finish	Vinyl	Cushioned	Seamless, coved	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	
3072	Wall finish	Vinyl	Cushioned	Wall vinyl full height	
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended	3000 mm height
6010	Cornice	Plasterboard	Paint	90mm to match ceiling finish	
7015	Observation	Safety glass	Clear	Through door/s	
7045	Observation	Safety glass	Paint	Internal window, safety glass	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900mm AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9007	Doors	Solid core/ safety glass	Paint	Single leaf, observation panel	1100mm clear opening; lockable from outside

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
1252	Furniture/ Fitting	Blind: Venetian integral	1	3	to windows & doors, controls outside room

Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quantit	Ele	CdW	HtW	WmW	Тар	Dns	Gas	Stm	Selection
7300	Camera : CCTV security	1	1	yes								optional, in ceiling dome

Services

Service ID	Service Category	Description	Quantity	Remarks			
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services			
6030	Lighting	Special: downlights		sealed, dimmable			
6060	Lighting	Special: night lights		high level, dimmable			
9060	Power	Special: for equipment	1	CCTV camera in ceiling			



