

# Design Guidelines for Hospitals and Day Procedure Centres

## Standard Components Room Data Sheets

**Room Name** Shower - Patient

**Room Code** SHPT

**Area M2** 4

### Description Special Requirement

The Shower - Patient is a room containing a shower and a handbasin for patients in multi-bed rooms to shower or wash, either independently or with nurse assistance.

Acoustics: Sound attenuation level - high; Acoustic privacy required.

Body Protected electrical area

Additional Design Considerations:

- Access is required for commode chairs
- The floor must not have a raised hob
- The door will require escape hardware to allow staff access in an emergency

### Room Fabric and outline specifications

					Remarks
1025	Floor finish	Vinyl, non slip	Studded	Seamless, coved	tiles also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	or tiles for tiled floor
3070	Wall finish	Vinyl	Prefinished	Wall vinyl full height	to wet areas; tiles also acceptable
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900mm AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9001	Doors	Solid Core	Paint	Single leaf	910mm clear; Outward opening; privacy latch; emerg release

### Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
530	Furniture/ Fitting	Basin vanity top	1	1	optional
3400	Metalwork	Coat hook	1	2	
4800	Metalwork	Curtain track, shower	1	1	
6152	Furniture/ Fitting	Dispenser: disposable glove	2	1	
6154	Furniture/ Fitting	Dispenser: paper towel	2	1	to handbasin
6156	Furniture/ Fitting	Dispenser: soap	2	1	to handbasin
8450	Metalwork	Grab rail - Shower	1	1	
9200	Metalwork	Hook, for catheter bag	1	1	optional
10800	Metalwork	IV hook	1	1	optional
13700	Metalwork	Mirror	1	1	
20650	Metalwork	Soap/ shampoo holder	1	1	
23700	Metalwork	Towel rail	1	1	

### Fixtures, Equipment and associated services

# Design Guidelines for Hospitals and Day Procedure Centres

## Standard Components Room Data Sheets

Room Name **Shower - Patient**

Room Code **SHPT**

FFE ID	Description	Grp	Quant	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
3120	Basin: vanity	1	1	___	yes	___	yes	yes	yes	___	___	or handbasin
47400	Shower: hand-held	1	1	___	yes	___	yes	yes	yes	___	___	

### Services

Service ID	Service Category	Description	Quantity	Remarks
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
5019	HVAC	Exhaust		Refer to Part E Building Services
6000	Lighting	General		
8000	Nurse Call	Patient / Nurse call	1	+ indicator button & light, water proof
8010	Nurse Call	Nurse assist call	1	+ indicator button & light, water proof
8080	Nurse Call	Emergency call	1	+ indicator button & light
9001	Power	GPO: Double	1	
9015	Power	GPO: Cleaner	1	