Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name

Shower - Staff

Room Code SHST

Area M2

2

Description Special Requirement

A shower room for staff use. The Staff Shower may be gender specific or unisex.

Acoustic: Sound attenuation- medium; Acoustic privacy is required.

Room F	Remarks				
1025	Floor finish	Vinyl, non slip	Studded	Seamless, coved	tiles also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	or tiles for tiled floor
3070	Wall finish	Vinyl	Prefinished	Wall vinyl full height	to wet area; tiles also acceptable
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
8000	Door protection	Vinyl	Prefinished	Kickplate, 300mm high	Equal to Acrovyn
9001	Doors	Solid Core	Paint	Single leaf	850mm clear opening; privacy latch

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
3400	Metalwork	Coat hook	1	2	
4800	Metalwork	Curtain track, shower	1	1	
13700	Metalwork	Mirror	1	1	optional
20650	Metalwork	Soap/ shampoo holder	1	1	

Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quantit	Ele	CdW	HtW	WmW	Тар	Dns	Gas	Stm	Selection
47500	Shower with fixed rose	1	1		yes		yes	yes	yes			

Services

Service ID	Service Category	Description	Quantity	Remarks
4033	Hydraulics	Floor drain	1	
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
5019	HVAC	Exhaust		Refer to Part E Building Services
6000	Lighting	General		





02-Nov-04

Issue 1