

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name **Staff Room**

Room Code **SRM**

Area M2 15

Description Special Requirement

The Staff Room is used by staff for respite, rest and relaxation during tea and meal breaks, especially where it is difficult for staff to use centrally located facilities including at night. The room may also be used for small meetings or tutorials and for the storage of staff resources or library materials. An external outlook is desirable.

Acoustics: Sound attenuation level - high; Acoustic privacy is required.

Room Fabric and outline specifications

Remarks

1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	to tea bench
1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom; 48 oz.	vinyl also acceptable
2010	Skirting	Vinyl	Prefinished	Feather edged, 150mmH	or floor vinyl coved skirting
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	to sink bench, tiles also acceptable
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
7001	Windows				desirable
8000	Door protection	Vinyl	Prefinished	Kickplate, 300mm high	Equal to Acrovyn
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel	850mm clear opening, lockable

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
1050	Furniture/ Fitting	Bench: laminate	1	1	with inset sink/ drainer
4410	Furniture/ Fitting	Cupboard: under bench	1	1	adjustable shelf
4430	Furniture/ Fitting	Cupboard: drawer unit	1	1	under bench
4460	Furniture/ Fitting	Cupboard: wall mounted	1	1	over bench, adjustable shelf
6154	Furniture/ Fitting	Dispenser: paper towel	2	1	to sink
6156	Furniture/ Fitting	Dispenser: soap	2	1	to sink
17360	Furniture/ Fitting	Pinboard, fabric covered	1	1	900mm x 900mm
19990	Furniture/ Fitting	Shelving unit - microwave	1	1	over bench
23410	Furniture/ Fitting	Television bracket, wall mounted	1	1	optional

Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quantit	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
5000	Boiling water unit	1	1	yes	yes	___	___	yes	yes	___	___	
48800	Sink & drainer : single	1	1	___	yes	___	___	yes	yes	___	___	

Services

Service ID	Service Category	Description	Quantity	Remarks
1006	Communications	Voice / Data outlet - double	1	

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name **Staff Room**

Room Code SRM

Service ID	Service Category	Description	Quantity	Remarks
1090	Communications	TV: MATV	1	optional
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
6000	Lighting	General		
8040	Nurse Call	Annunciator		to be audible in this room
9001	Power	GPO: Double	2	1 over bench
9060	Power	Special: for equipment	3	fridge, BWU, microwave
9060	Power	Special: for equipment	1	TV, optional