## **Design Guidelines for Hospitals and Day Procedure Centres**

# **Standard Components Room Data Sheets**

Room Name	Staff Station	Room Code SSTN				
Area M2	14					
Description Special Requirement						
	Acoustics: Sound attenuation level - Medium; acou	stic privacy required.				
	Special Design Requirements: - Staff Station is to have set down area for disable - Lockable stable doors may be provided for additi					

### **Room Fabric and outline specifications**

1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	carpet also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	or featheredged skirting over carpet
3000	Wall finish	Paint	Acrylic, washable		
5007	Ceiling	Plasterboard	Paint	Bulkhead	optional
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	

### **Fittings and Furniture**

<b>Fitting ID</b>	Category	Fitting	Grp	Quantity	Selection
11465	Furniture/ Fitting	Keyboard shelf, drop down	1	2	optional
17362	Furniture/ Fitting	Pinboard, fabric covered	2	1	to upstand of staff station
21250	Furniture/ Fitting	Staff station, laminate/ timber	1	1	with countertop (resinate/laminate)

#### Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quantit	Ele	CdW	HtW	WmW	Тар	Dns	Gas	Stm	Selection
68700	Xray viewer, 2 screen	1	1	yes								recessed

### Services

Service ID	Service Category	Description	Quantity	Remarks
1006	Communications	Voice / Data outlet - double	2	
5000	HVAC	Heating, Ventilation & Airconditioning	Ventilation & Airconditioning Refer to Part E	
6000	Lighting	General		
6030	Lighting	Special: downlights		dimmable for night lighting, optional
6055	Lighting	Special: task light- built in		under countertop
7050	Medical Gases	Gas Alarm Panel	1	as required
8040	Nurse Call	Annunciator	1	
9001	Power	GPO: Double	4	
9060	Power	Special: for equipment	1	X-ray viewer
10005	Security	Duress alarm	1	







Remarks