

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

| Room Name | Store - Equipment | Room Code STEQ |
|----------------------------|---|----------------|
| Area M2 | 20 | |
| Description | The Equipment Store is used for the storage of medical equipment when not in use and recharging of electrical items. Space is required for parking of mobile equipment including IV poles, wheelchairs, lifting equipment, trolleys, cradles and commode chairs for the Unit. Hooks will be required for hanging equipment. | |
| Special Requirement | | |

Room Fabric and outline specifications

| | | | | | Remarks |
|------|-----------------|--------------|-------------------------|--------------------------------|--|
| 1000 | Floor finish | Vinyl | Standard slip resistant | Seamless, coved | |
| 2000 | Skirting | Vinyl | Prefinished | Floor vinyl coved, 150mmH | |
| 3000 | Wall finish | Paint | Acrylic, washable | | |
| 4020 | Wall protection | Composite | Prefinished PVC | Crash rail at 900mm AFFL | Equal to Acrovyn, to equipment parking areas |
| 5030 | Ceiling | Plasterboard | Prefinished | Drop-in tiles, 600x1200 | |
| 6030 | Cornice | Aluminium | Powdercoat | 24mm shadow angle | |
| 8010 | Door protection | Composite | Prefinished PVC | Protection plate to 900mm AFFL | Equal to Acrovyn |
| 8040 | Door protection | Composite | Prefinished PVC | To door frame | Equal to Acrovyn |
| 9010 | Doors | Solid Core | Paint | 1 1/2 leaf | 1400mm clear opening; Lock set |

Fittings and Furniture

| Fitting ID | Category | Fitting | Grp | Quantity | Selection |
|------------|--------------------|---------------------------|-----|----------|---------------------|
| 7200 | Metalwork | Equipment hook | 1 | 4 | on mounting plate |
| 19970 | Furniture/ Fitting | Shelving unit, heavy duty | 1 | 1 | to 1 wall |
| 24400 | Metalwork | Whiteboard | 1 | 1 | 900 X 900, optional |

Fixtures, Equipment and associated services

Services

| Service ID | Service Category | Description | Quantity | Remarks |
|------------|------------------|--|----------|-----------------------------------|
| 5000 | HVAC | Heating, Ventilation & Airconditioning | | Refer to Part E Building Services |
| 6000 | Lighting | General | | |
| 9001 | Power | GPO: Double | 6 | for equipment recharging |