

# Design Guidelines for Hospitals and Day Procedure Centres

## Standard Components Room Data Sheets

Room Name Toilet - Disabled

Room Code WCDS

Area M2 5

**Description**  
**Special Requirement**

A toilet and handbasin for use by disabled persons with or without assistance. The Room shall comply with AS 1428; Baby change facilities may also be located in this room.

Acoustics: Sound attenuation level - High - Acoustic privacy.

### Room Fabric and outline specifications

### Remarks

1000	Floor finish	Vinyl	Standard slip resistant	Seamless, covered	tiles also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl covered, 150mmH	or tiles for tiled floor
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	to basin, tiles also acceptable
5030	Ceiling	Plasterboard	Prefinished	Drop-in tiles, 600x1200	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900mm AFFL	Equal to Acrovyn; both sides
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn; both sides
9001	Doors	Solid Core	Paint	Single leaf	910mm clear outward opening, privacy latch, emergency release

### Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
390	Furniture/ Fitting	Baby change table	1	1	optional
3410	Metalwork	Coat hook	1	2	1 at 1000mm AFFL
6154	Furniture/ Fitting	Dispenser: paper towel	2	1	to handbasin
6156	Furniture/ Fitting	Dispenser: soap	2	1	to handbasin
6160	Furniture/ Fitting	Dispenser: toilet paper	2	1	
8420	Metalwork	Grab rail : WC disabled use	1	2	
13700	Metalwork	Mirror	1	1	

### Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quant	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
3050	Basin : hand, disabled	1	1	___	yes	___	yes	yes	yes	___	___	short lever taps/ lever mixer
55650	Toilet suite : disabled use	1	1	___	yes	___	___	yes	yes	___	___	

### Services

Service ID	Service Category	Description	Quantity	Remarks
4033	Hydraulics	Floor drain		
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
5019	HVAC	Exhaust		Refer to Part E Building Services
6000	Lighting	General		
8000	Nurse Call	Patient / Nurse call	1	+ indicator button & light, optional

## Design Guidelines for Hospitals and Day Procedure Centres

### Standard Components Room Data Sheets

Room Name **Toilet - Disabled**

Room Code **WCDS**

Service ID	Service Category	Description	Quantity	Remarks
8010	Nurse Call	Nurse assist call	1	+ indicator button & light, optional
8080	Nurse Call	Emergency call	1	+ indicator button & light, optional
9001	Power	GPO: Double	1	optional