

# Design Guidelines for Hospitals and Day Procedure Centres

## Standard Components Room Data Sheets

Room Name Toilet - Patient

Room Code WCPT

Area M2 4

### Description Special Requirement

Room containing a toilet and handbasin for patients in multi-bed rooms or adjacent to communal patient areas. The door will be fitted with escape hardware to allow staff access in an emergency.

Acoustics: Sound attenuation level - High. Acoustic privacy required.

Body protected electrical area

### Room Fabric and outline specifications

### Remarks

1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	tiles also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	or tiles for tiled floor
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	tiles also acceptable
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900mm AFFL	Equal to Acrovyn; both sides
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn; both sides
9001	Doors	Solid Core	Paint	Single leaf	910mm clear outward opening, privacy latch, emergency release

### Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
530	Furniture/ Fitting	Basin vanity top	1	1	optional
3410	Metalwork	Coat hook	1	1	
6152	Furniture/ Fitting	Dispenser: disposable glove	2	1	
6154	Furniture/ Fitting	Dispenser: paper towel	2	1	to basin, optional
6156	Furniture/ Fitting	Dispenser: soap	2	1	to basin, optional
6160	Furniture/ Fitting	Dispenser: toilet paper	2	1	
8400	Metalwork	Grab rail - WC	1	2	1 behind toilet, 1 to side
9200	Metalwork	Hook, for catheter bag	1	1	optional
10800	Metalwork	IV hook	1	1	optional
13700	Metalwork	Mirror	1	1	

### Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quantit	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
3120	Basin: vanity	1	1	___	yes	___	yes	yes	yes	___	___	or handbasin
55605	Toilet suite : patient	1	1	___	yes	___	___	yes	yes	___	___	

### Services

## Design Guidelines for Hospitals and Day Procedure Centres

### Standard Components Room Data Sheets

Room Name **Toilet - Patient**

Room Code WCPT

Service ID	Service Category	Description	Quantity	Remarks
4033	Hydraulics	Floor drain	1	
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
5019	HVAC	Exhaust		Refer to Part E Building Services
6000	Lighting	General		
8000	Nurse Call	Patient / Nurse call	1	+ indicator button & light
8010	Nurse Call	Nurse assist call	1	+ indicator button & light
8080	Nurse Call	Emergency call	1	+ indicator button & light
9001	Power	GPO: Double	1	
9015	Power	GPO: Cleaner	1	
9040	Power	Body protected		