

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name Toilet - Staff

Room Code WCST

Area M2 3

Description A toilet and handbasin for staff use. Staff only access may be required.
Special Requirement Acoustics: Sound attenuation level - high; Acoustic privacy required.

Room Fabric and outline specifications

Item	Material	Finish	Notes	Remarks
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved tiles also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH or tiles for floor tiles
3000	Wall finish	Paint	Acrylic, washable	
3060	Wall finish	Vinyl	Prefinished	Splashback tiles also acceptable
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle
8000	Door protection	Vinyl	Prefinished	Kickplate, 300mm high Equal to Acrovyn; both sides
9001	Doors	Solid Core	Paint	Single leaf 850mm clear opening, privacy latch, emergency release

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
3410	Metalwork	Coat hook	1	1	
6154	Furniture/ Fitting	Dispenser: paper towel	2	1	to basin
6156	Furniture/ Fitting	Dispenser: soap	2	1	to basin
6160	Furniture/ Fitting	Dispenser: toilet paper	2	1	
13700	Metalwork	Mirror	1	1	
19910	Furniture/ Fitting	Shelf - vanity	1	1	

Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quantity	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
2850	Basin : handwash - small	1	1	___	yes	___	yes	yes	yes	___	___	Type C
55600	Toilet suite: standard	1	1	___	yes	___	___	yes	yes	___	___	

Services

Service ID	Service Category	Description	Quantity	Remarks
4033	Hydraulics	Floor drain	1	
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
5019	HVAC	Exhaust		Refer to Part E Building Services
6000	Lighting	General		
9000	Power	GPO: Single	1	optional