

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name Treatment Room

Room Code TRMT

Area M2 15

Description
Special Requirement

The Treatment Room provides a controlled environment, privacy and facilities for carrying out consultations, examinations and treatments which may include wound dressings.

Acoustics: Sound attenuation level - high; Acoustic privacy is required.

Body Protected electrical area

Room Fabric and outline specifications

Remarks

1000	Floor finish	Vinyl	Standard slip resistant	Seamless, covered	
2000	Skirting	Vinyl	Prefinished	Floor vinyl covered, 150mmH	
3000	Wall finish	Paint	Acrylic, washable		
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 dado	
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900mm AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9013	Doors	Solid Core	Paint	1 1/2 leaf, observation panel	1400mm clear opening; Lock set

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
1050	Furniture/ Fitting	Bench: laminate	1	1	
1465	Furniture/ Fitting	Bracket: suction bottle	2	1	
1470	Metalwork	Bracket: sharps	2	1	
3350	Furniture/ Fitting	Clock - battery operated	1	1	
4410	Furniture/ Fitting	Cupboard: under bench	1	1	adjustable shelf
4470	Furniture/ Fitting	Cupboard: wall mounted, lockable	1	1	over bench, adjustable shelf
4600	Metalwork	Curtain track, bed	1	1	to door opening
6152	Furniture/ Fitting	Dispenser: disposable glove	2	1	3 compartments
6154	Furniture/ Fitting	Dispenser: paper towel	2	1	to basin
6156	Furniture/ Fitting	Dispenser: soap	2	1	to basin
6158	Furniture/ Fitting	Dispenser: soap antiseptic	2	1	to basin
12900	Metalwork	Louvered panel, for storage-bins	1	2	over bench, optional

Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quantit	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
3100	Basin : scrub - large	1	1	___	yes	___	yes	yes	yes	___	___	Type A
31700	Light : examination, ceiling	1	1	yes	___	___	___	___	___	___	___	
68700	Xray viewer, 2 screen	1	1	yes	___	___	___	___	___	___	___	

Services

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name **Treatment Room**

Room Code **TRMT**

Service ID	Service Category	Description	Quantity	Remarks
1006	Communications	Voice / Data outlet - double	2	
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
6001	Lighting	General : colour corrected		
7000	Medical Gases	O2	1	
7020	Medical Gases	Medical Air	1	optional
7040	Medical Gases	Suction	1	
8000	Nurse Call	Patient / Nurse call	1	+ indicator button & light
8005	Nurse Call	Patient call handset	1	call button on the handset
8010	Nurse Call	Nurse assist call	1	+ indicator button & light
8080	Nurse Call	Emergency call	1	+ indicator button & light
9000	Power	GPO: Single	6	to patient services panel
9001	Power	GPO: Double	1	
9010	Power	GPO: Single - emergency power	2	to patient services panel
9015	Power	GPO: Cleaner	1	
9040	Power	Body protected		
9060	Power	Special: for equipment	3	XRV, light, refrigerator