

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name Ultra-Isolation Facility: Staff Change

Room Code UIF-SC

Area M2 5

Description Special Requirement

Room for staff to change and shower on entry or exit from the ultra-isolation facility. The shower is required in cases of accidental contamination.

Acoustics: Acoustic privacy is required.

Additional Design Considerations:

- Door to adjacent Dirty Utility to permit exit only - no re-entry from the Staff Change/ shower.

Room Fabric and outline specifications

Remarks

1025	Floor finish	Vinyl, non slip	Studded	Seamless, coved	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	
3035	Wall finish	Vinyl	Prefinished	Wall vinyl full height	
5021	Ceiling	Plasterboard	Paint, washable	Water resistant, flush set, suspended	Epoxy paint
6015	Cornice	Plasterboard	Paint	Flush coved between wall & ceiling	
8000	Door protection	Vinyl	Prefinished	Kickplate, 300mm high	Equal to Acrovyn, both sides
9001	Doors	Solid Core	Paint	Single leaf	910 clear opening; privacy latch

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
3400	Metalwork	Coat hook	1	4	
4800	Metalwork	Curtain track, shower	1	1	
6153	Furniture/ Fitting	Dispenser: moisturiser	2	1	to handbasin
6154	Furniture/ Fitting	Dispenser: paper towel	2	1	to handbasin
6156	Furniture/ Fitting	Dispenser: soap	2	1	to handbasin
6158	Furniture/ Fitting	Dispenser: soap antiseptic	2	1	
6160	Furniture/ Fitting	Dispenser: toilet paper	2	1	
13820	Furniture/ Fitting	Mirror with shelf	1	1	

Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quantity	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
2800	Basin: handwash - medium	1	1	___	yes	___	yes	yes	yes	___	___	Type B/C
47500	Shower with fixed rose	1	1	___	yes	___	yes	yes	yes	___	___	
55600	Toilet suite: standard	1	1	___	yes	___	___	yes	yes	___	___	in-wall cistern

Services

Service ID	Service Category	Description	Quantity	Remarks
4033	Hydraulics	Floor drain	1	
5005	HVAC	Air conditioning - special		
5019	HVAC	Exhaust		
6000	Lighting	General		Recessed, sealed

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name

Ultra-Isolation Facility: Staff Change

Room Code UIF-SC

Service ID	Service Category	Description	Quantity	Remarks
9000	Power	GPO: Single	1	