

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name **X-ray Viewing and Reporting**

Room Code **XRRR**

Area M2 12

Description Special Requirement

Room within a Clinical or Diagnostic Unit for reviewing and reporting of patient imaging film or computerised images.

Acoustics: Sound attenuation - medium; Acoustic privacy is required

Room Fabric and outline specifications

					Remarks
1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom; 48 oz.	vinyl also acceptable
2010	Skirting	Vinyl	Prefinished	Feather edged, 150mmH	or floor vinyl covered skirting
3000	Wall finish	Paint	Acrylic, washable		
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
7010	Observation	Glass	Clear	Through door/s	
8000	Door protection	Vinyl	Prefinished	Kickplate, 300mm high	Equal to Acrovyn
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel	910mm clear opening

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
1120	Furniture/ Fitting	Bench, workstation	1	1	to 2 sides of room
3350	Furniture/ Fitting	Clock - battery operated	1	1	
17310	Furniture/ Fitting	Pigeon hole unit	1	2	above bench, vertical slots for X-Rays
17360	Furniture/ Fitting	Pinboard, fabric covered	1	2	above bench
24400	Metalwork	Whiteboard	1	1	900 x1200, optional

Fixtures, Equipment and associated services

Services

Service ID	Service Category	Description	Quantity	Remarks
1006	Communications	Voice / Data outlet - double	5	1per workstation + 1- printer
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
6000	Lighting	General		
6005	Lighting	Dimmable		for image viewing
9000	Power	GPO: Single	9	2 per workstation + 1- printer